

# SMOKE OR FIRE IN THE COMPUTER ROOM 1156 HALON IN MANUAL MODE

If it is **not safe**, Exit the computer room through the **nearest** exit.

IF THIS OCCURS:		DO THIS:	OR DO THIS:
BLUE “VESDA LEVEL 1” STROBE	LEVEL 1 ALARM	<b>SMOKE OR FIRE?</b> Locate source. Remove power to system (EPO if necessary)	<b>IS THE ISSUE RESOLVED?</b>
BLUE “VESDA LEVEL 1” STROBE & “VESDA LEVEL 2” HORN/STROBE	LEVEL 2 ALARM	<b>FIRE REMAINS AFTER POWER REMOVED?</b> Use extinguisher if it is safe to do so <b>NEED IMMEDIATE HALON RELEASE?</b> MANUAL MODE will not allow automatic Halon release Pull Halon MANUAL RELEASE; exit room <b>NEED SPRINKLER MANUAL CHARGE?</b> Operate MANUAL CHARGE (at lockbox)	You know what caused this alarm and the cause (short circuit, dusty work) has been resolved, or does not require Halon release  Stay near HALON ABORT BUTTON
HALON HORN(S) ONLY AFTER MANUAL RELEASE	LEVEL 3 ALARM	<b>HALON RELEASE NEEDED?</b> MANUAL MODE will not allow automatic Halon release Pull Halon MANUAL RELEASE; exit room <b>HALON RELEASE IN 30 SECONDS!</b> Exit computer room <b>NEED SPRINKLER MANUAL CHARGE?</b> Operate MANUAL CHARGE (at lockbox)	<b>If Halon horn(s) activated, PRESS AND HOLD Halon ABORT BUTTON</b>  Call Alameda County Fire Dept x31051 or 510-486-6015 and report this information
FIRE ALARM BELL	BUILDING FIRE ALARM	<b>NO VESDA STROBES FLASHING; NO VESDA HORNS?</b> Most likely a fire alarm has been activated elsewhere in the building Stop work and exit the building	