

SMOKE OR FIRE IN THE COMPUTER ROOM 1275 NORMAL OPERATIONS

If it is <u>not safe</u>, Exit the computer room through the nearest exit.			
BLUE STROBE & PULSATING HORN	<p style="text-align: center; background-color: yellow;">LEVEL 1 ALARM</p> <ul style="list-style-type: none"> HSSD level 1 or 2, (low or medium levels of smoke) HSSD level 2, Blowers are shut down 	<p>SMOKE OR FIRE? Locate source. Remove power to system (EPO if necessary)</p> <p>FIRE REMAINS AFTER POWER REMOVED? Use extinguisher if it is safe to do so Stay near HALON ABORT BUTTON in case smoke detectors see Halon as smoke</p> <p>NEED IMMEDIATE HALON RELEASE? Pull Halon MANUAL RELEASE; exit room</p>	<p style="color: green;">SITUATION RESOLVED?</p> <p>You know what caused this alarm and the cause (short circuit, dusty work) has been resolved, or does not require Halon release</p>
BLUE AND YELLOW STROBES, & PULSATING HORN	<p style="text-align: center; background-color: yellow;">LEVEL 2 ALARM</p> <ul style="list-style-type: none"> HSSD level 3 (high level of smoke) Lieberts shut down EPO activated 	<p>FIRE REMAINS AFTER AUTO EPO? Use extinguisher if it is safe to do so Stay near HALON ABORT BUTTON in case smoke detectors see Halon as smoke</p> <p>NEED IMMEDIATE HALON RELEASE? Pull Halon MANUAL RELEASE; exit room</p>	<p>Stay near HALON ABORT BUTTON</p> <p style="color: red;">If red strobe and continuous horn activated, PRESS AND HOLD Halon ABORT BUTTON</p>
RED STROBE & CONTINUOUS HORN	<p style="text-align: center; background-color: yellow;">LEVEL 3 ALARM</p> <ul style="list-style-type: none"> Halon release in 30 seconds building alarm activated 	<p>HALON RELEASE IN 30 SECONDS! Exit computer room, unless:</p> <p>NEED IMMEDIATE HALON RELEASE? Pull Halon MANUAL RELEASE; exit room</p> <p>NEED TO ABORT HALON? Press and hold Halon ABORT BUTTON</p>	<p>Call Alameda County Fire Dept x31051 or 510-486-6015 and report this information</p>
FIRE ALARM BELL & CLEAR STROBE	<p style="text-align: center; background-color: yellow;">BUILDING FIRE ALARM</p>	<p>NO OTHER STROBES FLASHING; NO PULSATING HORNS? Most likely a fire alarm has been activated elsewhere in the building Stop work and exit the building</p>	